



ABN 22 005 827 814

HAZKEM PTY. LTD.
Suite 12, 1020 Doncaster Road
EAST DONCASTER VIC 3109

LPG & FUEL SYSTEMS DESIGN
SERVICE STATION & DEPOT DESIGN
DANGEROUS GOODS CONSULTING
DG WAREHOUSE DESIGN

CERTIFICATE OF COMPLIANCE – DESIGN

To:
Whom it may concern

From:
Hazkem Pty Ltd
Suite 12, 1020 Doncaster Rd

East Doncaster Vic 3109

Item: TRANSTANK SELF BUNDED FUEL STORAGE TANKS

Flammable and combustible liquid tanks nominal capacities of: 2250 litres (T2.25)
4500 litres (T4.5)
12,000 litres (T12)
20,000 litres (T20)
30,000 litres (T30)
55,000 litres (T55)

Combustible liquid nominal capacities of: 68,000 litres (T68)
80,000 litres (T80)
90,000 litres (T90)
105,000 litres (T105)
108,000 litres (T108)
108,000 litres (T108E)
110,000 litres (T110)

I have examined the design and I certify that the tanks and tank arrangement have been constructed in accordance with the relevant codes as detailed below.
The tanks for flammable liquid use must be fitted with emergency vents.

Design Documents.

Australian Standards:-	AS1940 (part 5.9 and 5.14)	The storage and handling of flammable and combustible liquids
	AS1692,	Tanks for flammable and combustible liquids
	AS 1657 (when applicable)	Fixed platforms, walkways, stairways and ladders – Design, construction and installation

I also note that this tank design for capacities up to and including the T80, has passed all tests required for acceptance by UL and ULC
All tanks are pressure tested before they leave the factory.

Signed

Phil Kemm
member AIDGC Date 23.05.2011